

Recorded in Official Records, Orange County
Hugh Nguyen, Clerk-Recorder



NO FEE

* \$ R 0 0 0 7 6 0 4 3 7 3 \$ *

201585000507 12:35 pm 06/15/15

7 SC4 Z01

0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00

Exempt per Gov't Code 6103

RETURN TO: Jo Ann Corey
Irvine Ranch Water District
P.O. Box 57000
15600 Sand Canyon Avenue
Irvine, CA 92619-7000

NOTICE OF EXEMPTION
(State Guidelines 15062)

County Clerk's Filing Stamp

TO: Orange County Clerk-Recorder
12 Civic Center Plaza, Room 101
Santa Ana, CA 92701

FROM: Irvine Ranch Water District (Applicant/Lead Agency)
P.O. Box 57000
15600 Sand Canyon Avenue
Irvine, CA 92619-7000

Project Name: East Irvine Zone 1 to 3 Booster Pump Station Pipe & Meter Replacement

Project Location: Sand Canyon Avenue/Trabuco Road, City of Irvine (see Exhibit "A")

County: Orange

Description of Nature, Purpose and Beneficiaries of Project:

The existing Zone 1 to 3 flow meter is located in a below grade vault near the intersection of Sand Canyon Avenue and Trabuco Road in the City of Irvine. The flow meter measures the amount of drinking water that is transferred through a section of the IRWD drinking water system. Recent site inspections indicated that the pipe adjacent to the flow meter is corroded and the location of existing vault is impeding proper meter maintenance. Additionally, improved accuracy is desired.

This project will replace the corroded piping and replace the existing turbine flow meter with a magnetic flow meter which historically, has proven to better read the flow levels. The existing vault will be demolished and replaced with a new above-ground vault and piping.

POSTED

JUN 15 2015

HUGH NGUYEN, CLERK-RECORDER

BY: [Signature] DEPUTY

FILED

JUN 15 2015

HUGH NGUYEN, CLERK-RECORDER

BY: [Signature] DEPUTY

Name of Public Agency Approving
and Carrying out this Project:

Irvine Ranch Water District (IRWD)
15600 Sand Canyon Avenue, Irvine, CA 92618

Contact Person: Jo Ann Corey, Engineering Technician III

Area Code 949

Phone 453-5326

Exempt Status: (check one)

- Ministerial (Sec 21080(b)(1); (State Guidelines Sec. §15268))
 Declared Emergency (Sec 21080(b)(3); State Guidelines Sec. §15269(a))
 Emergency Project (Sec 21080(b)(4); (State Guidelines Sec. §15269(b)(c))
 X Categorical Exemption (State Guidelines Sec. §15301)
 Categorical Exemption (State Guidelines Sec. §15302)
 Categorical Exemption (State Guidelines Sec. §15303)
 Categorical Exemption (State Guidelines Sec. §15306)
 Statutory Exemption State code number (State Guidelines §15282)

Reasons why project is exempt:

Class 1 consists of the operation, repair, maintenance, or minor alteration of existing public or private structures, facilities, mechanical equipment, or topographical features, involving negligible or no expansion of use beyond that existing at the time of the lead agency's determination.

Submission of this form is optional. Local agencies may file this form with the county clerk pursuant to Public Resources Code Section 21152(b). The filing of the notice starts a 35-day statute of limitations on court challenges to the approval of the project under Public Resources Code Section 21167(d). Failure to file the notice results in the statute of limitations being extended to 180 days.

Jo Ann Corey, Engineering Technician III
Staff Member Responsible for Preparation

Leshu Bankovsk
District Secretary

6/12/15
Date

POSTED

JUN 15 2015

HUGH NGUYEN, CLERK-RECORDER

BY: *[Signature]* DEPUTY


FILED

JUN 15 2015

HUGH NGUYEN, CLERK-RECORDER

BY: *[Signature]* DEPUTY

EXHIBIT "A"



FILED

JUN 15 2015

HUGH NGUYEN, CLERK-RECORDER

BY:  DEPUTY

IRVINE

POSTED

JUN 15 2015

HUGH NGUYEN, CLERK-RECORDER

BY:  DEPUTY

LOCATION MAP

N.T.S.